

## DECLARATION OF CONFORMITY

January 15, 2020

This Declaration of Conformity is issued under the sole responsibility of Temprite Company.  
Temprite Company declares the following products comply with:

-Directive 2014/68/EU of the European Parliament and of the Council of 15 May 2014 on the harmonization of the laws of the Member States relating to the making available on the market of pressure equipment.

**Quality Certificate No.:** HSB IE-18-09-014

**Classification:** Group 2 Gases

**T max.:** +160°C, **T min.:** 0°C

**Category I (PV: 50 to 200 bar-Liters):** *Conformity Assessment Procedure: Module A (No Notified Body Involvement)*

**Oil Separators:** Models 501, 502, 503, 504, 505, 600, 601, 602, 603, 604, 605, 900, 901, 902, 903, 904, 905, 912, 914, 915, 920, 921, 922, 923 all with or without alpha/numeric prefixes and/or suffixes.

**Receivers:** Model 1.5, 2.8, 6 all with or without alpha/numeric prefixes and/or suffixes.

**Category II (PV: 200 to 1000 bar-Liters):** *Conformity Assessment Procedure: Module H, Quality Certificate No.:* HSB IE-18-09-014

**Oil Separators:** Models 133, 135, 506, 507, 606, 607, 632, 924, 925, 926, 927 all with or without alpha/numeric prefixes and/or suffixes.

**Oil Reservoirs:** Models 47058, 47080, 47115, 47154 all with or without alpha/numeric prefixes and/or suffixes.

**Drier Shells:** Model 48 with or without alpha/numeric prefixes and/or suffixes.

**Receivers:** Model V2, V7, 2, 8, 10 all with or without alpha/numeric prefixes and/or suffixes.

**Category III (PV: 1000 to 3000 bar-Liters):** *Conformity Assessment Procedure: Module H, Quality Certificate No.:* HSB IE-18-09-014

**Oil Separators:** Models 137, 138, 139 (at 130 Bar), 928, 930 all with or without alpha/numeric prefixes and/or suffixes.

**Oil Reservoirs:** Models RES 7, 12, 17, RES 23 all with or without alpha/numeric prefixes and/or suffixes.

**Drier Shells:** Models 148, 248 all with or without alpha/numeric prefixes and/or suffixes.

**Receivers:** Models 10, 12, 14, 20, 60, 80, 120 all with or without alpha/numeric prefixes and/or suffixes.

**Category IV (PV: > 3000 bar-Liters):** *Conformity Assessment Procedure: Module H1, Quality Certificate No.:* HSB IE-18-09-014

**Oil Separator:** Model 139 (at 140 Bar) with or without alpha/numeric prefix and/or suffix.

**Receivers:** Models 16, 18 all with or without alpha/numeric prefixes and/or suffixes.

**Notified Body (for Categories II, III, and IV only):**

Hartford Steam Boiler Ireland Ltd

28 Windsor Place, Lower Pembroke Street, Dublin 2.

Dublin

Ireland

Notified Body number : 2833

**Safety Accessories:**

Safety accessories and pressure relief devices to be provided and installed by others.

**Compliance to Harmonized and Other Reference Standards:**

EN 15614-1 – Specification and qualification of welding procedures for metallic materials

EN 9606, EN 287, and EN 14732 – Qualification of Permanent Joining Personnel


EN 10204:2004 – Metallic Materials – Types of inspection documents

ASME Code Section IX, Div. 1 – Qualification of Permanent Joining Personnel and Procedures.

UL 207 – Refrigerant-Containing Components and Accessories

CSA STD. C22.2 NO 140.3-March 2015 – Refrigeration Equipment – Refrigerant Containing Parts

Signed,



Thomas Schmidt  
President – Temprite Company